

# Closed Loop Precise Hall AC/DC Current Sensor CYHCS-LF

This Hall Effect current sensor is based on closed loop compensating principle and can be used for accurate measurement of DC and AC current, pulse currents etc. The output of the transducer reflects the real wave of the current carrying conductor.

Product Characteristics	Applications
<ul> <li>Excellent accuracy</li> <li>Very good linearity</li> <li>Small size and encapsulated</li> <li>Less power consumption</li> <li>Current overload capability</li> </ul>	<ul> <li>Photovoltaic equipment</li> <li>General Purpose Inverters</li> <li>AC/DC Variable Speed Drivers</li> <li>Battery Supplied Applications</li> <li>Uninterruptible Power Supplies (UPS)</li> <li>Switched Mode Power Supplies</li> </ul>

#### **ELECTRICAL DATA**

Part number	CYHCS-LF1000A	CYHCS-LF2000A	
Nominal input current	1000A	2000A	
Measuring range	0-2000A	0-3000A	
Turns ratio	1:5000		
Measuring resistance	with Vc=±15V, @±1000Amax, ≤25Ω, @±1500Amax, ≤10Ω,		
	with Vc=±24V, @±2000Amax, ≤20Ω, @±3000Amax, ≤2Ω		
Supply voltage	±15VDC ~ ±24VDC		
Nominal output current	200mA	400mA	
Accuracy at +25°C	±0.2% for rated current 1000A~2000A		
Current consumption	with Vc=±15V ≤45mA + Output current, with Vc=±24V ≤50mA + Output current,		
Galvanic isolation	50Hz, 1min, 6kV		
Secondary internal resistance	Ta=25°C, 28 Ω		

#### **ACCURACY DYNAMIC PERFORMANCE**


Zero offset current Ta=25°C	< ±0.2mA
Magnetic Offset current IP→0	< ±0.2mA
Thermal drift of offset current	IP=0, Ta=-10°C ~ +70°C, ±0.5mA
Response time	<1µs
Accuracy	± 0.2% for rated current 1000A~2000A
Linearity	≤0.1%FS
Bandwidth(-3dB)	DC150kHz
di/dt	>100A/µs

#### **GENERAL DATA**

Operating temperature	-25°C ~ +85°C
Storage temperature	-40°C ~ +100°C

http://www.cy-sensors.com

## **Dimensions (mm)**











#### **Sensor Connections**

1) For Measurement of Bidirectional Current



2) For Measurement of Unidirectional Current



Two diodes for instance IN4007 must be connected at the output of the sensor in order to guarantee the sensor to work well.

### **Operating instructions**

- 1. Connect the terminals of power source, output respectively and correctly, never make wrong connection for DC current.
- 2. Temperature of the primary conductor should not exceed 100 °C.
- 3. Dynamic performances (di/dt and the response time) are the best with a single bar completely filling the primary hole.
- 4. In order to achieve the best magnetic coupling, the primary windings have to be wound over the top edge of the device.

Tel.: +49 (0)8121 - 2574100

Fax: +49 (0)8121- 2574101 Email: info@cy-sensors.com

http://www.cy-sensors.com